

# ***Augusta County Emergency Services Officers Association***

*Augusta County Government Center  
P.O. Box 590 – 18 Government Center Lane  
Verona, Virginia 24482*



## ***Fire-EMS***

### ***Standard Operating Guideline***

<b>Section:</b>	<b>4 Fire Operational Information</b>
<b>Title:</b>	<b>Annual Pump/Hose/Ladder Testing</b>
<b>Date:</b>	<b>August 2008 (Revised September 2013)</b>

### **PUMP/HOSE/LADDER TESTING**

Fire Departments must conduct annual pump, hose, and ladder testing to maintain performance and ISO ratings.

Pump test should be performed in accordance with NFPA 1901, and 1911.

Hose test should be performed in accordance with NFPA 1961.

Ladder test should be performed in accordance with NFPA 1932. This testing can be coordinated by ACFR but will be the financial responsibility of each agency.

Records of testing shall be maintained.

Test forms are available from the Augusta County Fire-Rescue Chief.